



NOTES:

1. MATERIALS, CONSTRUCTION AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH CURRENT EDITION OF SANDY CITY STANDARD SPECIFICATIONS AND DETAILS FOR MUNICIPAL CONSTRUCTION, ADDENDUMS AND SPECIAL PROVISIONS THERETO, AND AS DIRECTED BY THE CITY ENGINEER, OR HIS AUTHORIZED REPRESENTATIVE.
2. ALL REINFORCING STEEL SHALL BE INTERMEDIATE GRADE 40, AND SHALL HAVE A MINIMUM OF TWO INCHES COVER OR CLEARANCE FROM ALL SURFACES AND OPENINGS, UNLESS OTHERWISE SPECIFIED.
3. CONTRACTOR'S OPTION TO CUT STEEL IN FIELD.
4. ALL CONCRETE SHALL BE CLASS AAKAE, UNLESS OTHERWISE SPECIFIED.
5. FLOW-LINE ELEVATIONS, PIPE SIZES AND LOCATIONS SHALL BE SHOWN ON OTHER DRAWINGS.
6. UNDER CONDITIONS WHERE PIPE SIZE, PIPE TYPE OR EARTH OR EARTH COVER IS CRITICAL, USE MODIFIED OUTLET BOX.
7. USE D AND L SUPPLY MODEL I-3494 FRAME AND LID OR EQUIVALENT, AND SHALL BE MANUFACTURED IN A UNITED STATES FOUNDRY.
8. MACHINE ALL BEARING AND SEAT SURFACES TO PREVENT ROCKING OF COVER.
9.  INDICATES 96% COMPACTION REQUIRED.
10.  INDICATES CLASS AAKAE CONCRETE.

1	CC	UPDATE	1/2010	 <p>STANDARD DETAIL SW-04</p> <p>STANDARD CURB OUTLET BOX WITH COVER AND FRAME</p> <p>SCALE: NONE</p>
NO.	AUTHORIZED BY	REVISIONS	DATE	